

# UTKARSH ENGINEERING SERVICES (MOB-9369099324)

Valid Up to-17/12/2024

Certificate No.: UES/KIMS/LE-01/22


Date-18/06/2023


## Report on Examination of Hoist/Lift Under Section 28 of Factories Act

(Rule 55-A of The UP Factories Act-1950)

- 1-Name of Occupier/Factory : M/s Great Ganges Education Society
- 2-Address of the factory : Khasra No.:236 & 327,Kanpur Lucknow Highway  
Gadan Khera Bypass, Unnao, U.P.-209801
- 3-Type of Hoist or Lift & Identification No. or description : Passenger Lift, Sr. No.: 3/STE-B4, Cap: 408 Kgs.  
Make: Sharp Engineers U/C. Unik Elevators
- 4- Date of construction : 2020
- 5- Design and construction: Are all parts of the Lift/Hoist is in good mechanical construction, Sound material and adequate strength? : Yes
- 6-Maintenance: Are all the following parts of the Lift/Hoist properly maintained & in good working order? If not state the defects found.
- Enclosure of Hoist way : O.K.
  - Landing and cage gate. : O.K.
  - Interlock on gates. : O.K.
  - Other gates fastenings. : O.K.
  - Cage, Platform, Fitting guides & buffers : O.K.
  - Over running devices. : O.K.
  - Suspension Ropes/Chains. : O.K.
  - Safety gears. : O.K.
  - Warm/spur gearing. : O.K.
  - Other electronic equipments. : O.K.
  - Brakes. : O.K.
  - Other Vital Parts & Components.. : All parts found in good condition.
- 7- What parts were inaccessible? : None
- 8- Repaires, renewals, alteration if any required & period in which to be executed. : Not required.
- 9- Max. safe working load subject to repairs in (5). : 408 Kgs. (Only for 6 Passengers)
- 10- Other. : Load test carried out at 510 Kgs.  
& found satisfactory for safe use.

We Certified That on 18/06/2023 We Thoroughly Examined The Above Mentioned Hoist/Lift And That The Above is a Correct Report of Our Result. Certificate Valid Up To: 17/12/2024

  
**Mahender Kumar Verma**  
(Competent person)  
CP-UP/SEC.-28,29&31  
INST./46(I,II&III)/2021

  
**Uday Raj Sharma (Proprietor)**  
UTKARSH ENGINEERING SERVICES  
LIG-63, RATANLAL NAGAR  
KANPUR-208022

**Utkarsh Engineering Services**  
LIG-63, Ratan Lal Nagar  
Kanpur-208022  
Mo-9369099324